

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085BU0068**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Distributor <i>Vertreiber</i>	CAVAGNA GROUP S.P.A. - divisione RECA - Via Matteotti, 5, I-25012 Viadana di Calvisano (BS)
Product Category <i>Produktart</i>	gas fittings: Pressure regulator for LPG (4302)
Product Description <i>Produktbezeichnung</i>	Pressure regulator for LPG with automatic changeover, overpressure relief valve (PRV) and fixed outlet pressure optionally with testing-stub
Model <i>Modell</i>	924 N
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: 544/0218/1519 from 26.03.2018 (FGL)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 16129 (01.08.2013)

Date of Expiry / File No. 24.05.2028 / 18-0038-GEA
Ablaufdatum / AZ

24.04.2018 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
LPG	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
924 N	outlet pressure: 30,0 mbar inlet pressure range: 1,0...16,0 (P); 0,7...16,0 (LPG) bar nominal pressure rating: PN 16 nominal flow rate: 1,5 kg/h	for Caravans
924 N	outlet pressure: 29/37/50 mbar inlet pressure range: 1,0...16,0 (P); 0,7...16,0 (LPG) bar nominal pressure rating: PN 16 nominal flow rate: 1,5...3,0 kg/h	not for Caravans

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

ambient temperature range: -20...+50 ° C

connection: at the input side G.1, G.13, G.14, G.18, G.23 (annex G); at the outlet side H.7, H.9, H.11, H.19 (annex H)

PRV-response pressure: max. 150 mbar

In Macedonia the conformaty approval will be accepted if the EU-Gas Appliance Regulation (EU/2016/426) is transferred into national law by Macedonia.